

SOUND ABSORPTION AREA FOR OBJECT


Measured and evaluated according to SS-EN ISO 354 and ISO 20189

Client: Abstracta

Object: Sky

Size [mm]: w = 846 h = 591 d = 120

1/3 octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0
125	0.09
250	0.29
500	0.32
1000	0.4
2000	0.42
4000	0.49
N ₁₀ = 31	

**CONDITIONS**

Date of test:	2018-09-23	Object volume:	0.06	m ³
Date:	2019-02-28	Rev. room volume:	200	m ³

Test report: KTH-MWL ABSTRACTA SKY 20180923

Signature: Lars Wester